



# City of Salisbury

Jacob R. Day, Mayor

## ADDENDUM 3

**CONTRACT NO. 121-17**

**Park Water Treatment Plant High Service Pumps**

**DATE ISSUED:** May 9, 2017

**RESPONSE DUE:** May 15, 2017 at 2:30 P.M. (local time)

This addendum is intended to correct, change, add, delete, or supplement the drawings, special conditions, and/or specifications, and is hereby made part of the bidding documents on which the General Contract will be based. Acknowledge receipt of this addendum by signing below and returning no later than May 15<sup>th</sup>, 2017.

1. What is the contract duration?

Answer: Substantial completion shall be accomplished within one hundred and twenty (120) days of the Notice to Proceed. Contract Final Completion shall be accomplished within one hundred and eighty (180) days of Notice to Proceed.

2. Is this a grant funded project?

Answer: Yes, a portion of the funding is through the Maryland Department of the Environment.

3. What parts are to be made available from the Successful Vendor per section IV item 3c page 40?.

Answer: Mechanical seal kit, and major repair kits for each pump. Parts shall be original manufacturer's equipment.

4. What fittings are to be replaced?

Answer: Fittings shall be replaced for pumps 1 ,2 ,3 and 5. Please refer to attachment 1 of the bid document.

\_\_\_\_\_  
Sign for identification

\_\_\_\_\_  
Printed Name

Approved by:

*Jennifer Miller*

Jennifer Miller  
Assistant Director of Internal Services, Procurement Division

---

Department of Internal Services - Procurement Division  
125 N. Division St., Rm 104 Salisbury, MD 21801  
410-548-3190 (fax) 410-548-3192  
www.salisbury.md